

NetBotz[®] Door Switch Sensor for Rooms or Third-Party Racks (NBES0302)—Installation Instructions

Inventory



Door switch sensor with 15.24-m (50-ft) cable (1)



203-mm (8-in) tie wrap (20)





#4 x 1/2-in screw (4)



Adhesive cable tie holder (10)





RJ-45 coupling (1)

Installation



Caution: Make sure you connect this sensor to a **Sensor** port on applicable NetBotz products. See your NetBotz product documentation for details.



Note: You can extend the length of the sensor cable up to 30.5 m (100 ft) using the RJ-45 coupling and standard CAT-5 cabling.



Note: Use adhesive cable tie holders and tie wraps to secure the sensor cable.

Room door-mounting option



Rack door-mounting option





Customer support and warranty information is available at the APC Web site, www.apc.com.

990-3378A 10/2008

@ 2008 American Power Conversion. All rights reserved. All APC trademarks are property of American Power Conversion. Other trademarks are property of their respective owners.